




John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

January 17, 2013

Stephen A. Renner
Franklin County Sanitary Engineers
280 East Broad Street
Columbus, OH 43215

Franklin County
Timberlake Water System
COMMUNITY PWS
PWS ID: OH2501812

Dear Mr. Renner:

The Public Water System serving TIMBERLAKE WATER SYSTEM is in violation of the Ohio Administrative Code (OAC) 3745-82-02 for failure to maintain finished water manganese levels below the secondary maximum contaminant level (SMCL) in December 2012.

- *Finished water manganese levels were above the SMCL of 0.05 mg/L on December 17 and 18, 2012. Each exceedance is a violation of Ohio Administrative Code 3745-82-02.*

Please provide an explanation on what has been done to prevent these exceedances from occurring in the future within 15 days of the date of this letter. If you have any questions please call me at (614) 728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: Franklin County Health Department
ec: CDO DDAGW AA (State Violation)

CO/cl 2501812(M)DEC2012