



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

REGISTERED DIRECTOR'S JOURNAL

Dan Kiely
301 North Clematis St, Suite 3000
West Palm Beach, FL 33401

Effective Date: January 24, 2013

Certified Mail

Re: 2013 Conditioned Licenses to Operate a Public Water System

Dear Mr. Kiely:

Enclosed are the 2013 licenses to operate (LTOs) a public water system (PWS) for the Glen at State Line MHP 1 and MHP 2 (PWS ID# OH5002812 and OH5002112). In accordance with Ohio Revised Code (ORC) § 6109.21 and Ohio Administrative Code (OAC) Rule 3745-84-06, the LTOs are hereby issued with conditions due to violations of drinking water regulations at the PWSs. In accordance with OAC Rule 3745-84-04, PWSs are required to display the yellow, conditioned licenses where they are clearly visible to the residents and general public; and to notify the residents of the conditioned status of the licenses in the consumer confidence reports, pursuant to OAC Chapter 3745-96.

The LTOs are conditioned through January 30, 2014, with the following actions:

1. Comply with all current and subsequent chemical monitoring schedules, in accordance with OAC Chapter 3745-81.
2. Comply with all total coliform bacteria monitoring requirements, including both routine and repeat sampling, in accordance with OAC Rule 3745-81-21 and OAC Rule 3745-81-42.
3. Comply with the total coliform maximum contaminant level, in accordance with OAC Rule 3745-81-14.
4. Complete all applicable requirements in accordance with OAC Rules 3745-81-81, 3745-81-82, and 3745-81-85, to address the Lead 90th percentile action level exceedances at both PWSs, including, but not limited to:
 - a. installing the approved orthophosphate feed equipment by no later than September 30, 2014;
 - b. complying with all of the conditions identified in the Director's approval letters; and
 - c. continuing to conduct public education until the approved orthophosphate feed equipment is installed.
5. Comply with all PWS LTO renewal requirements, in accordance with OAC Chapter 3745-84.


If the requirements of the conditioned LTO(s) are fulfilled, the PWS(s) may be eligible for green, unconditioned licenses in the next renewal period. Should the PWS(s) fail to comply with these conditions, the LTO(s) may be suspended or revoked. A PWS with a suspended LTO may only operate as authorized by the Director, and a PWS with a revoked LTO is prohibited from producing water for human consumption. Human consumption is defined in OAC Rule 3745-81-01 to include, but is not limited to, drinking, food preparation, dishwashing, and hand washing. Additionally, owners and/or operators who fail to comply with Ohio's safe drinking water laws are subject to civil penalties of up to \$25,000.00 per day per violation under ORC § 6109.33. Operating with a suspended or revoked LTO may jeopardize other licenses, including the mobile home park license.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to ORC § 3745.04. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
77 South High Street, 17th Floor
Columbus, OH 43215

If you have any questions regarding this action, please contact Katie Hernandez at (614) 644-2752.

Sincerely,



Scott J. Nally, Director
Ohio Environmental Protection Agency

- cc: Mahoning County Health Department
Ohio Manufactured Homes Commission
Ed Janosky, Operator in Charge
- ec: Holly Kaloz, Manager, DDAGW-CO
Dave Maschak, DOCC, DDAGW-NEDO
Stivo DiFranco, Supervisor, DDAGW-NEDO
Chris Maslo, DDAGW-NEDO
Kimberly Rhoads, Office of Legal Services