



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 18, 2008

Re: Adams County
Hillcrest Nursing Home
Notice of Violation
Ohio EPA Permit No. OPX00011*AD
Correspondence (PWW)

Mr. Chris Inverso
Provider Services, Inc.
16230 Taylor Drive
Danville, Ohio 43014

Dear Mr. Inverso:

We have received your self-monitoring report covering the months of October 2007 to March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Apr 2008	001	Dissolved Oxygen	1D Conc	6.0	5.8	4/4/2008
Apr 2008	001	Dissolved Oxygen	1D Conc	6.0	5.3	4/11/2008
Apr 2008	001	Dissolved Oxygen	1D Conc	6.0	5.7	4/25/2008
May 2008	001	Chlorine, Total Residual	1D Conc	0.019	.07	5/22/2008
Jun 2008	001	Chlorine, Total Residual	1D Conc	0.019	.07	6/12/2008
Jun 2008	001	Chlorine, Total Residual	1D Conc	0.019	.06	6/26/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions or comments, please feel free to contact me at (740) 380-5226.

Sincerely,



Patrick Hudnall
District Representative
Division of Surface Water

PH/dh

c: Mike Wisecarver
c: Dave Jenkins
c: Larry Burton