



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 13, 2008

**Re: Adams County  
Hillcrest Nursing Home  
Notice of Violation  
Ohio EPA Permit No. OPX00011\*AD  
Correspondence (PWW)**

Mr. Chris Inverso  
Provider Services, Inc.  
16230 Taylor Drive  
Danville, Ohio 43014

Dear Mr. Inverso:

We have received your self-monitoring report covering the months of October 2007 to March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Oct 2007	001	Dissolved Oxygen	1D Conc	6.0	5.6	10/5/2007
Oct 2007	001	Dissolved Oxygen	1D Conc	6.0	5.9	10/12/2007
Oct 2007	001	Dissolved Oxygen	1D Conc	6.0	5.5	10/26/2007
Nov 2007	001	Nitrogen, Ammonia (NH3)	30D Conc	2.3	3.35	11/1/2007
Nov 2007	001	Dissolved Oxygen	1D Conc	6.0	5.8	11/9/2007
Nov 2007	001	Nitrogen, Ammonia (NH3)	7D Conc	3.5	6.5	11/15/2007
Nov 2007	001	Dissolved Oxygen	1D Conc	6.0	5.9	11/16/2007
Dec 2007	001	Total Suspended Solids	30D Conc	12	27.	12/1/2007
Dec 2007	001	Nitrogen, Ammonia (NH3)	30D Qty	0.07	.14902	12/1/2007
Dec 2007	001	Nitrogen, Ammonia (NH3)	30D Conc	2.3	12.7	12/1/2007
Dec 2007	001	CBOD 5 day	30D Conc	10	20.	12/1/2007
Dec 2007	001	Dissolved Oxygen	1D Conc	6.0	5.6	12/7/2007
Dec 2007	001	Dissolved Oxygen	1D Conc	6.0	5.9	12/14/2007
Dec 2007	001	Total Suspended Solids	7D Conc	18	27.	12/15/2007
Dec 2007	001	Nitrogen, Ammonia (NH3)	7D Conc	3.5	12.7	12/15/2007
Dec 2007	001	Nitrogen, Ammonia (NH3)	7D Qty	0.11	.14902	12/15/2007
Dec 2007	001	CBOD 5 day	7D Conc	15	20.	12/15/2007
Jan 2008	001	Total Suspended Solids	30D Conc	12	13.	1/1/2008
Jan 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	2.3	11.55	1/1/2008
Jan 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.07	.14279	1/1/2008

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Jan 2008	001	CBOD 5 day	30D Conc	10	18.	1/1/2008
Jan 2008	001	Nitrogen, Ammonia (NH3)	7D Qty	0.11	.22653	1/15/2008
Jan 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	3.5	17.1	1/15/2008
Jan 2008	001	CBOD 5 day	7D Conc	15	22.	1/15/2008
Jan 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	3.5	6.	1/22/2008
Feb 2008	001	Dissolved Oxygen	1D Conc	6.0	5.6	2/1/2008
Feb 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	2.3	7.25	2/1/2008
Feb 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.07	.09746	2/1/2008
Feb 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	3.5	13.8	2/15/2008
Feb 2008	001	Nitrogen, Ammonia (NH3)	7D Qty	0.11	.18804	2/15/2008
Feb 2008	001	Dissolved Oxygen	1D Conc	6.0	5.6	2/28/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions or comments, please feel free to contact me at (740) 380-5226.

Sincerely,



Patrick Hudnall  
District Representative  
Division of Surface Water

PH/dh

c: Mike Wisecarver  
c: Dave Jenkins  
c: Larry Burton