



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 13, 2008

Re: Adams County
Village of Peebles
Notice of Violation
0PB00069*FD
Correspondence (PWW)

Mr. Dean Bailey, Village of Administrator
Village of Peebles
34 South Nixon Avenue
Peebles, Ohio 45660

Dear Mr. Bailey:

We have received your self-monitoring report covering the month of January 2008 to March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Limit Violations:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Jan 2008	001	Nitrogen, Ammonia (NH3	30D Qty	6.36	6.96784	1/1/2008
Jan 2008	001	Nitrogen, Ammonia (NH3	7D Qty	9.54	17.6586	1/8/2008
Mar 2008	001	Total Suspended Solids	30D Qty	31.79	37.3014	3/1/2008
Mar 2008	001	CBOD 5 day	30D Qty	15.90	23.0476	3/1/2008
Mar 2008	001	Total Suspended Solids	7D Qty	47.69	52.1077	3/15/2008
Mar 2008	001	CBOD 5 day	7D Qty	23.85	35.6967	3/15/2008
Mar 2008	001	CBOD 5 day	7D Qty	23.85	25.1365	3/22/2008

Frequency Violations:

Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
January 2008	1/1/2008	001	Phosphorus, Total (P)	1/Month	1	0
January 2008	1/1/2008	001	Nitrite Plus Nitrate,	1/Month	1	0
January 2008	1/8/2008	001	CBOD 5 day	2/Week	2	1
January 2008	1/8/2008	601	CBOD 5 day	2/Week	2	1

In addition to the frequency violations listed in the above table, Peak Flow Rate was not reported for the months of January 2008 and March 2008.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Should you have any questions, please feel free to contact me at (740) 380-5226.

Sincerely,



Patrick Hudnall
District Engineer
Division of Surface Water

PH/dh