



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 18, 2008

**Re:** Adams County  
Village of Seaman  
Notice of Violation  
Ohio EPA Permit No. 0PB00098\*FD  
Correspondence (PWW)

Mayor and Council  
Village of Seaman  
17806 State Route 247  
P.O. Box 248  
Seaman, Ohio 45679

Dear Mayor and Council:

We have received your self-monitoring report covering the month of March to June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2008	001	Fecal Coliform	7D Conc	2000	10000.	5/15/2008
May 2008	001	CBOD 5 day	7D Qty	10.22	10.5	5/15/2008
Jun 2008	001	Fecal Coliform	7D Conc	2000	10000.	6/1/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If you have any questions or comments, please contact me at (740) 380-5226.

Sincerely,

Patrick Hudnall  
District Representative  
Division of Surface Water

PH/dh