OhioEPA
State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 7, 2009

Re: Athens County
ODOT Torch Rest Area
Notice of Violation
Permit 0PP00087*CD
PQNCR
Correspondence (PWW)

Mr. Glenn Soles
Ohio Department of Transportation
2397 Jackson Pike
Bidwell, Ohio 45614

Dear Mr. Soles:

We have received your self-monitoring report covering the months of January through March 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Units	Limit	Reported Value	Violation Date
January 2009						
001	Nitrogen, Ammonia	30D Conc	mg/L	3.0	21.4	1/1/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	4.5	21.4	1/5/2009
February 2009						
001	Nitrogen, Ammonia	30D Conc	mg/L	3.0	9.1	2/1/2009
001	CBOD 5 day	30D Conc	mg/L	10	14	2/1/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	4.5	9.1	2/6/2009
001	Dissolved Oxygen	1D Conc	mg/L	6.0	4.6	2/6/2009
March 2009						
001	Dissolved Oxygen	1D Conc	mg/L	6.0	5.7	3/6/2009

***NOTES:**
1D Conc = Daily Average Concentration Value
1D Qty = Daily Average Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation is not satisfactory and we request, within ten days of receipt of this letter, written information as to what additional steps you will take to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh