



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

October 14, 2009

Re: Athens County
ODOT Torch Rest Area
SNC Notice of Violation
Permit 0PP00087*CD
Correspondence (PWW)

Mr. Glenn Soles
Ohio Department of Transportation
2397 Jackson Pike
Bidwell, Ohio 45614

Dear Mr. Soles:

We have received your self-monitoring reports covering the months of April through June 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Units	Limit	Reported Value	Violation Date
May 2009						
001	CBOD 5 day	30D Conc	mg/l	10	12.	5/1/2009

- *NOTES:**
- 1D Conc = Daily Average Concentration Value
 - 1D Qty = Daily Average Loading Value
 - 7D Conc = Weekly Average Concentration Value
 - 30D Conc = Monthly Average Concentration Value
 - 7D Qty = Weekly Average Loading Value
 - 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation is not satisfactory and we request, within ten days of receipt of this letter, written information as to what additional steps you will take to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in black ink, appearing to read "Abbot Stevenson". The signature is fluid and cursive, with a long horizontal stroke extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh