

7006 3450 0001 9054 6697

U.S. Postal Service™
CERTIFIED MAIL™ RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com®

OFFICIAL USE

Postage	\$.41
Certified Fee	2.65
Return Receipt Fee (Endorsement Required)	2.15
Restricted Delivery Fee (Endorsement Required)	
Total Postage & Fees	\$ 5.21



Sent To Raymond Croxford
 Street, Apt. No. or PO Box No. P.O. Box 683
 City, State, ZIP+4 Athens, OH 45701

PS Form 3800, August 2006 See Reverse for Instructions

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. 	<p>A. Signature <input checked="" type="checkbox"/> <u>Ray Croxford</u> <input type="checkbox"/> Agent <input checked="" type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name) <u>RM Croxford</u> C. Date of Delivery <u>8-15-07</u></p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes If YES, enter delivery address below: <input type="checkbox"/> No</p>
<p>1. Article Addressed to: <u>Raymond Croxford</u> <u>P.O. Box 683</u> <u>Athens, OH 45701</u></p>	<p>3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p>
<p>2. Article Number (Transfer from service label) <u>7006 3450 0001 9054 6697</u></p>	<p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

August 8, 2007

Re: Athens County
Knollwood MHP c/o Pine-Aire MHP
Reconnaissance Inspection
Ohio EPA Permit No. OPV00007*FD
NPDES Permit No. OH0050334
Correspondence (PWW)
Certified Mail 70063450000190546697

Mr. Raymond Croxford
P.O. Box 683
Athens, Ohio 45701

Dear Mr. Croxford:

On Friday, July 27, 2007, I conducted a reconnaissance inspection of the Knollwood MHP WWTP. Please see the attached inspection report for comments/concerns noticed during the inspection, and immediately take the necessary actions to bring the facility into compliance. We are recommending formal enforcement action be initiated due to the history of egregious violations associated with this facility.

If there are any questions, please contact me at (740) 380-5226.

Sincerely,

Patrick Hudnall
Division of Surface Water

PH/dh

Enclosure

c: Mike Cooper, Athens County Health Department

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
OPV00007	OH0050334	July 27, 2007	R	S	1

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Knollwood MHP WWTP c/o Pine Aire MHP P.O. Box 683 Athens, Ohio 45701	1:00	October 1, 2001
	Exit Time	Permit Expiration Date
	1:45	September 30, 2006

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
None.	740-797-4444
Name, Address and Title of Responsible Official	Phone Number
Raymond Croxford, Owner	740-797-4444

C. AREAS EVALUATED DURING INSPECTION

<u>U</u> Permit	<u>N</u> Flow Measurement	<u>N</u> Pretreatment
<u>U</u> Records/Reports	<u>N</u> Laboratory	<u>U</u> Compliance Schedules
<u>U</u> Operations & Maintenance	<u>M</u> Effluent/Receiving Waters	<u>U</u> Self-Monitoring Program
<u>U</u> Facility Site Review	<u>U</u> Sludge Storage/Disposal	<u> </u> Other
<u>M</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

Continued poor maintenance of the WWTP. Sand filters need cleaned. Trash trap needs emptied. Still no dechlorination unit. Insufficient amount of chlorine tablets in chlorination unit. Sludge drying beds need cleaned of weeds and dried sludge. Entire plant in a state of disrepair. Much infrastructure maintenance needed.



 Patrick Hudnall, Inspector, Ohio EPA, Southeast District Office

8/8/07

 Date



 Timothy M Campbell, Reviewer, Ohio EPA, Southeast District Office

8/8/07

 Date