



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 14, 2011

**Re:** Athens County  
Knollwood MHP c/o Pine-Aire MHP  
Reconnaissance Inspection  
Ohio EPA Permit No. 0PV00007\*FD  
NPDES Permit No. OH0050334  
Correspondence (PWW)

Mr. Raymond Croxford  
dba Knollwood MHP  
7343 Cameron Road  
Athens, Ohio 45701

Dear Mr. Croxford:

On June 16, 2011, I conducted a reconnaissance inspection at the Knollwood MHP wastewater treatment plant. The purpose of the inspection was to determine the operational condition of the plant. Access was limited as the fence was locked. No one represented the facility during the inspection.

The plant is in very poor condition and the following items need to be addressed as required by Part III of the NPDES permit:

1. The sand filters continue to be neglected. The beds are full of weeds. The walls are falling apart and need to be rebuilt.
2. There were no Chlorine tablets in the chlorinator. Chlorination must be provided immediately.
3. The NPDES permit contains a compliance schedule requiring installation of dechlorination. This has not been accomplished. Submit a Permit to Install with plans for a dechlorination system, and once approved, install the unit immediately.

As you are aware, the Ohio Attorney General recently negotiated a Consent Order against your facility containing injunctive relief and civil penalties because of the manner in which you have operated the wastewater treatment plant. You should make every effort to comply with the Consent Order and to return the facility to compliance with the Ohio Water Pollution Control Act, Revised Code Chapter 6111.

Please respond, in writing, within 30 days of receipt of this report, to Items 1 through 3 listed above. If you have any questions, please contact me at your convenience at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

Enclosure

c: Janean Webber, Ohio Attorney General's Office  
c: Larry Reeder, DSW, CO  
c: Athens County Health Department

# NPDES Compliance Inspection Report

## A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PV00007*FD	OH0050334	June 16, 2011	R	S	1

## B. FACILITY DATA

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
Raymond Croxford Knollwood Court Athens, Ohio	9:10 a.m.	October 1, 2001
	Exit Time	Permit Expiration Date
	9:25 a.m.	September 30, 2006

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
None	
Name, Address, & Title of Responsible Official	Phone Number
Ray Croxford, Owner dba Knollwood MHP 7343 Cameron Road Athens, Ohio 45701	(740) 541-5520

## C. AREAS EVALUATED DURING INSPECTION

<u>  N  </u> Permit	<u>  N  </u> Flow Measurement	<u>  N/A  </u> Pretreatment
<u>  N  </u> Records/Reports	<u>  N  </u> Laboratory	<u>  U  </u> Compliance Schedules
<u>  U  </u> Operations & Maintenance	<u>  U  </u> Effluent/Receiving Waters	<u>  N  </u> Self-Monitoring Program
<u>  N  </u> Facility Site Review	<u>  N  </u> Sludge Storage/Disposal	<u>      </u> Other
<u>  N  </u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)

## D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)

1. Operations - See attached letter items 1, 2 and 3
2. Effluent - See attached letter item 2
3. Compliance schedule - See attached letter item 3

  
 \_\_\_\_\_  
 Abbot Stevenson, Inspector, Ohio EPA, Southeast District Office

7/15/11  
 \_\_\_\_\_  
 Date

  
 \_\_\_\_\_  
 Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

7/15/11  
 \_\_\_\_\_  
 Date