



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 18, 2008

**Re:** Athens County  
Happy Valley Estates MHP  
Notice of Violation  
Permit OPV00531\*BD  
Correspondence (PWW)

Ms. Mary Harrison-Reed, Vice President  
6800 Baker Road  
Athens, Ohio 45701

Dear Ms. Harrison-Reed:

We have received your self-monitoring report covering the months of January to June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

- Discharge Monitoring Reports for station OPV00531001 for the months of January 2008 to April 2008 have not been received.

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.053	.15	5/1/2008
May 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	4.3	5/1/2008
May 2008	001	Dissolved Oxygen	1D Conc	6.0	5.9	5/4/2008
May 2008	001	Nitrogen, Ammonia (NH3)	1D Conc	1.5	4.8	5/4/2008
May 2008	001	Nitrogen, Ammonia (NH3)	1D Qty	0.080	.16	5/4/2008
May 2008	001	Dissolved Oxygen	1D Conc	6.0	5.8	5/18/2008
May 2008	001	Nitrogen, Ammonia (NH3)	1D Conc	1.5	8.	5/27/2008
May 2008	001	Nitrogen, Ammonia (NH3)	1D Qty	0.080	.27	5/27/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten (10) days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Happy Valley Estates MHP  
Page 2

Should you have any questions or concerns, feel free to contact me at (740) 380-5226.

Sincerely,



Patrick Hudnall  
District Representative  
Division of Surface Water

PH/dh

c: Elsea, Inc.