



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-8490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 24, 2009

**Re:** Athens County  
Happy Valley Estates MHP  
SNC Notice of Violation  
Permit 0PV00531\*BD  
Correspondence (PWW)

Mr. Asa Elsea, President  
Elsea, Inc.  
P.O. Box 580  
Circleville, Ohio 43113

Dear Mr. Elsea:

A review of the Discharge Monitoring Reports for the months of April through September 2009 indicates violations of the conditions of your NPDES permit at outfall 001. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Limit	Reported	Date
<b>April 2009:</b>						
001	pH	1D Conc	S.U.	6.5	2.81	4/16/2009
<b>May 2009:</b>						
001	Total Suspended Solids	30D Conc	mg/l	12	17.25	5/1/2009
001	Fecal Coliform	30D Conc	#/100ml	1000	10000	5/1/2009
001	Total Suspended Solids	7D Conc	mg/l	18	21	5/8/2009
001	Nitrogen, Ammonia	7D Conc	mg/l	3	5.5	5/8/2009
001	Fecal Coliform	7D Conc	#/100ml	2000	10000	5/15/2009
001	Chlorine	1D Conc	mg/l	0.019	0.4	5/21/2009
001	Total Suspended Solids	7D Conc	mg/l	18	30	5/22/2009
001	Chlorine	1D Conc	mg/l	0.019	0.2	5/28/2009
<b>June 2009:</b>						
001	Total Suspended Solids	30D Conc	mg/l	12	16.75	6/1/2009
001	Total Suspended Solids	7D Conc	mg/l	18	30	6/1/2009
001	Chlorine	1D Conc	mg/l	0.019	0.4	6/4/2009
001	Chlorine	1D Conc	mg/l	0.019	0.2	6/11/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	6/18/2009
001	Chlorine	1D Conc	mg/l	0.019	0.2	6/25/2009
<b>July 2009:</b>						
001	Total Suspended Solids	30D Conc	mg/l	12	27.6	7/1/2009
001	Total Suspended Solids	7D Conc	mg/l	18	88	7/1/2009
001	Chlorine	1D Conc	mg/l	0.019	0.4	7/2/2009
001	Chlorine	1D Conc	mg/l	0.019	0.4	7/9/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	7/16/2009

Outfall	Parameter	Type	Units	Limit	Reported	Date
001	Chlorine	1D Conc	mg/l	0.019	0.4	7/23/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	7/30/2009
<b>August 2009:</b>						
001	Chlorine	1D Conc	mg/l	0.019	0.2	8/6/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	8/13/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	8/20/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	8/27/2009
<b>September 2009:</b>						
001	Total Suspended Solids	30D Conc	mg/l	12	14	9/1/2009
001	Total Suspended Solids	7D Conc	mg/l	18	21	9/1/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	9/3/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	9/10/2009
001	Chlorine	1D Conc	mg/l	0.019	0.4	9/17/2009
001	Chlorine	1D Conc	mg/l	0.019	0.3	9/24/2009

Please be advised that failure to satisfy the reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Failure to report violations of the effluent limitations is also a violation of your NPDES permit. Please review Part 3 of the NPDES permit for reporting requirements.

Please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

- c: Tom Bouts, Operator
- c: Mary Harrison-Reed, Elsea, Inc.
- c: AS file