



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 7, 2009

Re: Athens County
Federal Hocking Middle Sr. High School
Notice of Violation
Permit OPT00047*CD
PQNCR
Correspondence (PWW)

Mr. Jim Patsey, Superintendent
Federal Hocking School District
8461 State Route 144
Stewart, Ohio 45778

Dear Mr. Patsey:

We have received your self-monitoring report covering the months of January through March 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Limit	Reported Value	Violation Date
January 2009						
001	Nitrogen, Ammonia	30D Conc	mg/L	3	8.67	1/1/2009
001	Nitrogen, Ammonia	7D Conc	mg/L	4.5	8.67	1/1/2009
001	Nitrogen, Ammonia	30D Qty	Kg/day	0.102	0.116	1/1/2009
February 2009						
001	Nitrogen, Ammonia	30D Conc	mg/L	3	24	2/1/2009
001	Nitrogen, Ammonia	7D Conc	mg/L	4.5	24	2/8/2009

***NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Failure to report violations of the effluent limitations is also a violation of your NPDES permit. Please review Part 3 of the NPDES permit for reporting requirements.

Please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Dr. George Wood, Principal