



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 18, 2008

**Re:** Athens County  
Cool Spot Convenience Store  
Notice of Violation  
Permit OPR00127  
Correspondence (PWW)

Mr. Bryan White, Owner  
25780 Brimstone Road  
Coolville, Ohio 45723

Dear Mr. White:

We have received your self-monitoring report covering the months of April to June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Apr 2008	001	Nitrogen, Ammonia (NH3)	1D Conc	4.5	10.	4/1/2008
Apr 2008	001	Nitrogen, Ammonia (NH3)	1D Qty	0.060	.06041	4/1/2008
Apr 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.040	.06041	4/1/2008
Apr 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	3.0	10.	4/1/2008
Apr 2008	001	CBOD 5 day	30D Conc	10	16.	4/1/2008
Apr 2008	001	CBOD 5 day	1D Conc	15	16.	4/1/2008
May 2008	001	Total Suspended Solids	30D Conc	12	20.	5/1/2008
May 2008	001	Total Suspended Solids	1D Conc	18	20.	5/6/2008
May 2008	001	Chlorine, Total Residual	1D Conc	0.019	.05	5/20/2008
Jun 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.013	.01345	6/1/2008
Jun 2008	001	Chlorine, Total Residual	1D Conc	0.019	.05	6/16/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Your explanation is not satisfactory and we request, within ten days of receipt of this letter, written information as to what additional steps you will take to prevent further occurrences.

Should you have any questions or concerns, feel free to contact me at (740) 380-5226.

Sincerely,



Patrick Hudnall  
District Representative  
Division of Surface Water

PH/dh