



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 16, 2008

**Re: Athens County
Capstone Village
Notice of Violation
Permit OPW00018*BD
Correspondence (PWW)**

Mr. Bob Prebe
8644 United Lane
Athens, Ohio 45701

Dear Mr. Prebe:

We have received your self-monitoring report covering the months of October 2007 to March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Limit Violations:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Oct 2007	001	Dissolved Oxygen	1D Conc	5	.36	10/1/2007
Oct 2007	001	Chlorine, Total Residual	1D Conc	.019	.1	10/1/2007
Oct 2007	002	Dissolved Oxygen	1D Conc	5	.21	10/1/2007
Oct 2007	002	Nitrogen, Ammonia (NH3)	30D Qty	.20	1.16729	10/1/2007
Oct 2007	002	Nitrogen, Ammonia (NH3)	30D Conc	1.5	12.85	10/1/2007
Oct 2007	002	Nitrogen, Ammonia (NH3)	7D Conc	2.3	12.85	10/1/2007
Oct 2007	002	Nitrogen, Ammonia (NH3)	7D Qty	.21	1.16729	10/1/2007
Oct 2007	002	Chlorine, Total Residual	1D Conc	.019	.21	10/1/2007
Oct 2007	001	Dissolved Oxygen	1D Conc	5	.33	10/8/2007
Oct 2007	001	Chlorine, Total Residual	1D Conc	.019	.11	10/8/2007
Oct 2007	002	Dissolved Oxygen	1D Conc	5	.24	10/8/2007
Oct 2007	002	Chlorine, Total Residual	1D Conc	.019	.21	10/8/2007
Oct 2007	001	Dissolved Oxygen	1D Conc	5	.86	10/16/2007
Oct 2007	001	Chlorine, Total Residual	1D Conc	.019	.05	10/16/2007
Oct 2007	002	Dissolved Oxygen	1D Conc	5	1.06	10/16/2007
Nov 2007	001	Nitrogen, Ammonia (NH3)	7D Qty	.26	.32305	11/1/2007
Nov 2007	001	Nitrogen, Ammonia (NH3)	30D Qty	.17	.32305	11/1/2007

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Feb 2008	002	CBOD 5 day	30D Qty	.90	.9084	2/1/2008
Mar 2008	002	Nitrogen, Ammonia (NH3)	7D Qty	.4	1.47252	3/1/2008
Mar 2008	002	Nitrogen, Ammonia (NH3)	7D Conc	4.5	16.21	3/1/2008
Mar 2008	002	Nitrogen, Ammonia (NH3)	30D Qty	.27	1.47252	3/1/2008
Mar 2008	002	Nitrogen, Ammonia (NH3)	30D Conc	3	16.21	3/1/2008
Mar 2008	001	Dissolved Oxygen	1D Conc	5	4.22	3/10/2008
Mar 2008	001	Dissolved Oxygen	1D Conc	5	4.04	3/25/2008
Mar 2008	002	Dissolved Oxygen	1D Conc	5	4.21	3/25/2008

Frequency Violations:

Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
Oct 2007	10/15/2007	002	Chlorine, Total Residual	1/2Weeks	1	0
Oct 2007	10/22/2007	001	Water Temperature	1/Week	1	0
Oct 2007	10/22/2007	001	Dissolved Oxygen	1/Week	1	0
Oct 2007	10/22/2007	002	Water Temperature	1/Week	1	0
Oct 2007	10/22/2007	002	Dissolved Oxygen	1/Week	1	0
Jan 2008	1/8/2008	001	Water Temperature	1/Week	1	0
Jan 2008	1/8/2008	001	Dissolved Oxygen	1/Week	1	0
Jan 2008	1/8/2008	002	Water Temperature	1/Week	1	0
Jan 2008	1/8/2008	002	Dissolved Oxygen	1/Week	1	0
March 2008	3/15/2008	001	Water Temperature	1/Week	1	0
March 2008	3/15/2008	001	Dissolved Oxygen	1/Week	1	0
March 2008	3/15/2008	002	Water Temperature	1/Week	1	0
March 2008	3/15/2008	002	Dissolved Oxygen	1/Week	1	0

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Should you have any questions or concerns, feel free to contact me at (740) 380-5226.

Sincerely,

A handwritten signature in black ink, appearing to read "Patrick Hudnall". The signature is written in a cursive style with a large initial "P".

Patrick Hudnall
District Representative
Division of Surface Water

PH/dh