



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 18, 2008

Re: Athens County
Capstone Village
Notice of Violation
Permit 0PW00018*BD
Correspondence (PWW)

Mr. Bob Prebe
8644 United Lane
Athens, Ohio 45701

Dear Mr. Prebe:

We have received your self-monitoring report covering the months of April to June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Limit Violations:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
Apr 2008	002	Nitrogen, Ammonia (NH3)	30D Conc	3	12.4	4/1/2008
Apr 2008	002	Nitrogen, Ammonia (NH3)	7D Conc	4.5	12.4	4/1/2008
Apr 2008	001	Dissolved Oxygen	1D Conc	5	3.9	4/4/2008
Apr 2008	002	Dissolved Oxygen	1D Conc	5	4.1	4/4/2008
Apr 2008	001	Dissolved Oxygen	1D Conc	5	3.4	4/11/2008
Apr 2008	002	Dissolved Oxygen	1D Conc	5	3.1	4/11/2008
Apr 2008	001	Dissolved Oxygen	1D Conc	5	1.1	4/18/2008
Apr 2008	002	Dissolved Oxygen	1D Conc	5	1.1	4/18/2008
May 2008	002	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.5	5/1/2008
May 2008	002	Nitrogen, Ammonia (NH3)	30D Qty	.20	0.22	5/1/2008
May 2008	002	Fecal Coliform	30D Conc	1000	2000.	5/1/2008
May 2008	001	Dissolved Oxygen	1D Conc	5	1.2	5/2/2008
May 2008	002	Dissolved Oxygen	1D Conc	5	1	5/2/2008
May 2008	001	Dissolved Oxygen	1D Conc	5	1.1	5/9/2008
May 2008	002	Dissolved Oxygen	1D Conc	5	1	5/9/2008
May 2008	001	Dissolved Oxygen	1D Conc	5	0.5	5/15/2008
May 2008	002	Dissolved Oxygen	1D Conc	5	.4	5/15/2008
May 2008	002	Nitrogen, Ammonia (NH3)	7D Qty	.21	0.22	5/15/2008
May 2008	002	Nitrogen, Ammonia (NH3)	7D Conc	2.3	2.5	5/15/2008
May 2008	002	Fecal Coliform	7D Conc	2000	2000.	5/15/2008

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2008	002	Dissolved Oxygen	1D Conc	5	.45	5/26/2008
May 2008	002	Chlorine, Total Residual	1D Conc	.019	.11	5/26/2008
May 2008	001	Chlorine, Total Residual	1D Conc	.019	.05	5/30/2008
May 2008	002	Chlorine, Total Residual	1D Conc	.019	.1	5/30/2008
Jun 2008	002	Nitrogen, Ammonia (NH3)	30D Conc	1.5	1.9	6/1/2008
Jun 2008	001	Dissolved Oxygen	1D Conc	5	1.9	6/9/2008
Jun 2008	001	Chlorine, Total Residual	1D Conc	.019	.16	6/9/2008
Jun 2008	002	Dissolved Oxygen	1D Conc	5	2.3	6/9/2008
Jun 2008	002	Chlorine, Total Residual	1D Conc	.019	0.1	6/9/2008
Jun 2008	001	Dissolved Oxygen	1D Conc	5	1.7	6/18/2008
Jun 2008	001	Chlorine, Total Residual	1D Conc	.019	.13	6/18/2008
Jun 2008	002	Dissolved Oxygen	1D Conc	5	2.2	6/18/2008
Jun 2008	002	Chlorine, Total Residual	1D Conc	.019	.09	6/18/2008
Jun 2008	001	Dissolved Oxygen	1D Conc	5	0.8	6/24/2008
Jun 2008	001	Chlorine, Total Residual	1D Conc	.019	.18	6/24/2008
Jun 2008	002	Dissolved Oxygen	1D Conc	5	0.7	6/24/2008
Jun 2008	002	Chlorine, Total Residual	1D Conc	.019	0.09	6/24/2008
Jun 2008	001	Dissolved Oxygen	1D Conc	5	0.4	6/30/2008
Jun 2008	001	Chlorine, Total Residual	1D Conc	.019	.15	6/30/2008
Jun 2008	002	Dissolved Oxygen	1D Conc	5	0.5	6/30/2008
Jun 2008	002	Chlorine, Total Residual	1D Conc	.019	.1	6/30/2008

Frequency Violations:

Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
April 2008	4/22/2008	001	Water Temperature	1/Week	1	0
April 2008	4/22/2008	001	Dissolved Oxygen	1/Week	1	0
April 2008	4/22/2008	002	Water Temperature	1/Week	1	0
April 2008	4/22/2008	002	Dissolved Oxygen	1/Week	1	0
May 2008	5/1/2008	001	Chlorine, Total Residual	1/2Weeks	1	0
May 2008	5/1/2008	002	Chlorine, Total Residual	1/2Weeks	1	0
June 2008	6/1/2008	001	Water Temperature	1/Week	1	0
June 2008	6/1/2008	001	Dissolved Oxygen	1/Week	1	0
June 2008	6/1/2008	002	Water Temperature	1/Week	1	0
June 2008	6/1/2008	002	Dissolved Oxygen	1/Week	1	0


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Capstone Village
Page 3

Should you have any questions or concerns, feel free to contact me at (740) 380-5226.

Sincerely,

A handwritten signature in cursive script, appearing to read "Patrick Hudnall".

Patrick Hudnall
District Representative
Division of Surface Water

PH/dh