



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 7, 2009

**Re:** Athens County  
Capstone Village  
Notice of Violation  
Permit 0PW00018\*BD  
PQNCR  
Correspondence (PWW)

Mr. Bob Prebe  
Capstone Village  
8644 United Lane  
Athens, Ohio 45701

Dear Mr. Prebe:

We have received your self-monitoring report covering the months of January through March 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
<b>January 2009</b>						
001	Nitrogen, Ammonia	30D Conc	mg/L	3	8.85	1/1/2009
001	Nitrogen, Ammonia	30D Qty	Kg/day	0.17	0.50	1/1/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	4.5	8.85	1/5/2009
001	Nitrogen, Ammonia	1D Qty	Kg/day	0.26	0.50	1/5/2009
<b>February 2009</b>						
001	Total Suspended Solids	30D Conc	mg/L	12	19	2/1/2009
001	Total Suspended Solids	30D Qty	Kg/day	0.68	1.08	2/1/2009
001	Nitrogen, Ammonia	30D Conc	mg/L	3	33.54	2/1/2009
001	Nitrogen, Ammonia	30D Qty	Kg/day	0.17	1.90	2/1/2009
001	CBOD 5 day	30D Conc	mg/L	10	26	2/1/2009
001	CBOD 5 day	30D Qty	Kg/day	0.57	1.48	2/1/2009
002	Nitrogen, Ammonia	30D Conc	mg/L	3	9.92	2/1/2009
002	Nitrogen, Ammonia	30D Qty	Kg/day	0.27	0.90	2/1/2009
001	Total Suspended Solids	1D Conc	mg/L	18	19	2/9/2009
001	Total Suspended Solids	1D Qty	Kg/day	1.02	1.08	2/9/2009
001	Nitrogen, Ammonia	1D Conc	mg/L	4.5	33.54	2/9/2009
001	Nitrogen, Ammonia	1D Qty	Kg/day	0.26	1.90	2/9/2009
001	CBOD 5 day	1D Conc	mg/L	15	26	2/9/2009
001	CBOD 5 day	1D Qty	Kg/day	0.85	1.48	2/9/2009
002	Nitrogen, Ammonia	1D Conc	mg/L	4.5	9.92	2/9/2009
002	Nitrogen, Ammonia	1D Qty	Kg/day	0.4	0.90	2/9/2009

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
002	Dissolved Oxygen	1D Conc	mg/L	5	4.4	2/13/2009
<b>March 2009</b>						
002	Nitrogen, Ammonia	30D Conc	mg/L	3	12.59	3/1/2009
002	Nitrogen, Ammonia	30D Qty	Kg/day	0.27	1.14	3/1/2009
001	Dissolved Oxygen	1D Conc	mg/L	5	3.47	3/6/2009
002	Dissolved Oxygen	1D Conc	mg/L	5	3.53	3/6/2009
002	Nitrogen, Ammonia	1D Conc	mg/L	4.5	12.59	3/9/2009
002	Nitrogen, Ammonia	1D Qty	Kg/day	0.4	1.14	3/9/2009
001	Dissolved Oxygen	1D Conc	mg/L	5	2.91	3/13/2009
002	Dissolved Oxygen	1D Conc	mg/L	5	2.97	3/13/2009
001	Dissolved Oxygen	1D Conc	mg/L	5	2.19	3/20/2009
002	Dissolved Oxygen	1D Conc	mg/L	5	2.05	3/20/2009
001	Dissolved Oxygen	1D Conc	mg/L	5	1.09	3/27/2009
002	Dissolved Oxygen	1D Conc	mg/L	5	1.05	3/27/2009

**\*NOTES:** 1D Conc = Daily Average Concentration Value  
 1D Qty = Daily Average Loading Value  
 7D Conc = Weekly Average Concentration Value  
 30D Conc = Monthly Average Concentration Value  
 7D Qty = Weekly Average Loading Value  
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson  
 Environmental Engineer  
 Permits and Enforcement Section  
 Division of Surface Water

AS/dh