



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 14, 2009

Re: Athens County
Arcadia Nursing Center
SNC Notice of Violation
NPDES Permit 0PR00096*CD
Correspondence (PWW)

Facility Manager
Arcadia Care Center
25675 Main Street
Coolville, Ohio 45723

To Whom it May Concern:

We have received your self-monitoring reports covering the months of April through June 2009 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Limit	Reported Value	Violation Date
April 2009						
001	Nitrogen, Ammonia	30D Qty	Kg/day	0.205	46146	4/1/2009
001	CBOD 5 day	30D Qty	Kg/day	0.409	144208	4/1/2009
001	Nitrogen, Ammonia	1D Qty	Kg/day	0.307	46146	4/24/2009
001	CBOD 5 day	1D Qty	Kg/day	0.614	144208	4/24/2009
May 2009						
001	Chlorine	1D Conc	mg/L	0.019	3.1	5/1/2009
001	Chlorine	1D Conc	mg/L	0.019	3.1	5/8/2009
001	Chlorine	1D Conc	mg/L	0.019	3.1	5/15/2009
001	Chlorine	1D Conc	mg/L	0.019	3.1	5/22/2009
001	Chlorine	1D Conc	mg/L	0.019	3.1	5/29/2009
June 2009						
001	Chlorine	1D Conc	mg/L	0.019	0.3	6/5/2009
001	Chlorine	1D Conc	mg/L	0.019	0.3	6/12/2009
001	Chlorine	1D Conc	mg/L	0.019	0.3	6/19/2009
001	Chlorine	1D Conc	mg/L	0.019	0.4	6/26/2009

Please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Should you have any questions or concerns, feel free to contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

- c: Mike Wisecarver
- c: Chris Catlett, Maintenance Supv.
- c: Mr. Chris Inverso, Provider Services, Inc.