



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 25, 2008

Re: Athens County
Bassett House
NPDES 0PX00008
Notice of Violation
Correspondence (PWW)

Mr. Rich Green
Health Recovery Services, Inc.
P.O. Box 724
Athens, Ohio 45701

Dear Mr. Green:

We have received your self-monitoring report covering the months of April to June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2008	001	Chlorine, Total Residual	1D Conc	.019	.4	5/9/2008
May 2008	001	Chlorine, Total Residual	1D Conc	.019	.5	5/23/2008
Jun 2008	001	Nitrogen, Ammonia (NH3)	7D Qty	0.035	.076	6/1/2008
Jun 2008	001	Nitrogen, Ammonia (NH3)	30D Qty	0.023	.076	6/1/2008
Jun 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	1.5	4.03	6/1/2008
Jun 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	2.3	4.03	6/1/2008

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Should you have any questions, please feel free to contact me at (740) 380-5226.

Sincerely,



Patrick Hudnall
District Engineer
Division of Surface Water

PH/dh

- c: Mark Rutter
- c: Jerry Smith, Buckeye Environmental