



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 22, 2008

Re: Athens County
City of Athens
Water Treatment Plant
Compliance Evaluation Inspection
NPDES Permit 01Z00000*HD
Correspondence (IWW)

Mayor and Council
City of Athens
8 East Washington Street
Athens, Ohio 45701

Dear Mayor and Council:

On July 15, 2008, Cynthia Yandrich and I conducted a Compliance Evaluation Inspection at the City of Athens water treatment plant (WTP). Crystal Kynard, Plant Supervisor represented the City of Athens and accompanied us during the inspection. The purpose of the inspection was to evaluate the status of the City's compliance with the terms and conditions set in the current National Pollutant Discharge Elimination System (NPDES) Permit.

The following observations were made during the inspection.

1. At the time of the inspection, there was no flow monitoring device in place to record the effluent flow rate. Crystal stated that the flow meter was out for repair and would be returned shortly. The flow meter must be put back in operation as soon as possible to ensure accurate flow monitoring. Please respond to this comment, in writing, outlining the cities time line to return the flow meter to service within ten (10) days.

A copy of my Compliance Evaluation Inspection report is enclosed. The assistance and cooperation received during the inspection was greatly appreciated. Should you have any further questions, please contact me at (740) 380-5226.

Sincerely,

Patrick Hudnall
District Representative
Division of Surface Water

PH/dh

Enclosure

c: Crystal Kynard, City of Athens WTP

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
01Z00000*FD	OH0030139	July 15, 2008	C	S	2

B. FACILITY DATA

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Athens WTP 395 W State St Athens, Ohio 45701	8:30 AM	March 1, 2004
	Exit Time	Permit Expiration Date
	9:00 AM	February 28, 2009

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Crystal Kynard, Operator	740-592-3344
Name, Address and Title of Responsible Official	Phone Number
City of Athens 8 East Washington Street Athens, Ohio 45701	740-592-3344

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>U</u> Flow Measurement	<u>N</u> Pretreatment
<u>S</u> Records/Reports	<u>S</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>S</u> Sludge Storage/Disposal	<u> </u> Other
<u>N/A</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

D. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


See attached inspection letter



Patrick Hudnall, Inspector, Ohio EPA, Southeast District Office

7/22/08

Date



Timothy M Campbell, Reviewer, Ohio EPA, Southeast District Office

7/22/08

Date