



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 28, 2008

**Re: Belmont County  
Barnesville WWTP  
Self-monitoring Report Violations  
Ohio EPA Permit #OPC00001\*GD  
Correspondence (PWW/Major)**

Mayor and Council  
Village of Barnesville  
132 N. Arch Street  
Barnesville, Ohio 43713

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of October 2007 through March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
<b>February 2008:</b>						
001	Total Suspended Solids	30D Conc	mg/L	30.0	36.5833	2/1/2008
001	Total Suspended Solids	7D Conc	mg/L	45.0	95.75	2/1/2008
001	Total Suspended Solids	30D Qty	Kg/day	148.0	482.018	2/1/2008
001	Total Suspended Solids	7D Qty	Kg/day	221.0	1376.16	2/1/2008
001	CBOD 5 day	30D Qty	Kg/day	123.0	148.639	2/1/2008
001	CBOD 5 day	7D Qty	Kg/day	197.0	412.585	2/1/2008
<b>March 2008:</b>						
001	Total Suspended Solids	7D Conc	mg/L	45.0	77.3333	3/1/2008
001	Total Suspended Solids	30D Qty	Kg/day	148.0	351.033	3/1/2008
001	Total Suspended Solids	7D Qty	Kg/day	221.0	1006.56	3/1/2008
001	Nitrogen, Ammonia	30D Qty	Kg/day	7.4	10.6121	3/1/2008
001	CBOD 5 day	7D Qty	Kg/day	197.0	300.472	3/1/2008
001	Total Suspended Solids	7D Qty	Kg/day	221.0	365.132	3/15/2008
001	Nitrogen, Ammonia	7D Qty	Kg/day	15.0	25.2107	3/15/2008


- \*NOTES:**
- 1D Conc = Daily Average Concentration Value
  - 1D Qty = Daily Average Loading Value
  - 7D Conc = Weekly Average Concentration Value
  - 30D Conc = Monthly Average Concentration Value
  - 7D Qty = Weekly Average Loading Value
  - 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

- c: Roger Deal, Village Admin., Village of Barnesville
- c: Gary Billman, Plant Supt., Village of Barnesville WWTP
- c: AS file