



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 7, 2009

Re: Belmont County
Barnesville WWTP
Self-monitoring Report Violations
Ohio EPA Permit #0PC00001*GD
Correspondence (PWW/Major)

Mayor and Council
Village of Barnesville
132 N. Arch Street
Barnesville, Ohio 43713

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of April through September 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Permit Limit	Reported	Date
July 2008:						
001	Dissolved Oxygen	1D Conc	mg/L	5.0	4.3	7/21/2008
August 2008:						
001	Dissolved Oxygen	1D Conc	mg/L	5.0	4.9	8/25/2008
001	Dissolved Oxygen	1D Conc	Kg/day	5.0	4.9	8/29/2008


- *NOTES:**
- 1D Conc = Daily Average Concentration Value
 - 1D Qty = Daily Average Loading Value
 - 7D Conc = Weekly Average Concentration Value
 - 30D Conc = Monthly Average Concentration Value
 - 7D Qty = Weekly Average Loading Value
 - 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

- c: Roger Deal, Village Admin., Village of Barnesville
- c: Gary Billman, Plant Supt., Village of Barnesville WWTP
- c: AS file