



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 21, 2010

**Re: Belmont County  
Barnesville WWTP  
Self-monitoring Report Violations  
Ohio EPA Permit #0PC00001\*HD  
Correspondence (PWW/Major)**

Mayor and Council  
Village of Barnesville  
132 N. Arch Street  
Barnesville, Ohio 43713

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of January through June 2010 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
<b>May 2010</b>						
001	Total Suspended Solids	30D Conc	mg/L	20	22.4	5/1/2010
001	Total Suspended Solids	7D Conc	mg/L	30	111	5/1/2010
001	Total Suspended Solids	30D Qty	Kg/day	98	123	5/1/2010
001	Total Suspended Solids	7D Qty	Kg/day	148	637	5/1/2010

\*NOTES: 1D Conc = Daily Average Concentration Value  
 1D Qty = Daily Average Loading Value  
 7D Conc = Weekly Average Concentration Value  
 30D Conc = Monthly Average Concentration Value  
 7D Qty = Weekly Average Loading Value  
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Failure to report violations of the effluent limitations is also a violation of your NPDES permit. Please review Part 3 of the NPDES permit for reporting requirements.

Please inform this office in writing, within ten days of receipt of this notification, as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

Enclosures

- c: Roger Deal, Village Admin., Village of Barnesville (w/enclosures)
- c: Gary Billman, Plant Supt., Village of Barnesville WWTP (w/enclosures)
- c: AS file