

**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 23, 2011

Re: Belmont County
Bethesda WWTP
Reconnaissance Evaluation Inspection
Ohio EPA Permit #0PB00001*FD
NPDES Permit #OH0021121
Correspondence (PWW)

Mayor and Council
Village of Bethesda
P.O. Box 95
Bethesda, Ohio 43719

Dear Mayor and Council Members:

On June 9, 2011, I conducted a Reconnaissance Inspection at the Village of Bethesda's wastewater treatment plant (WWTP). The purpose of the inspection was to determine the facility's compliance status with the terms and conditions of the NPDES permit, federal number OH0021121, state number 0PB00001*FD. Wastewater samples were not taken. A copy of the inspection report form is attached.

In April, the following effluent violations occurred:

Outfall	Parameter	Type*	Units	Permit Limit	Reported	Date
001	pH	1D Conc	S.U.	6.5	6.4	4/12/2011
001	pH	1D Conc	S.U.	6.5	6.4	4/13/2011
001	pH	1D Conc	S.U.	6.5	6.4	4/14/2011
001	pH	1D Conc	S.U.	6.5	6.0	4/20/2011

NOTES: 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

On May 20, 2011 we received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

No response is required at this time. If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in black ink, appearing to read 'Abbot Stevenson', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

Enclosure

c: Tim Zdanski, Administrator, Village of Bethesda
c: TCCI Laboratories, Inc.

NPDES
Compliance Inspection Report

A. NATIONAL DATA SYSTEM CODING

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0PB00001*FD	OH0021121	June 9, 2011	R	S	1

B. FACILITY DATA

Name & Location of Facility Inspected	Entry Time	Permit Effective Date
Bethesda WWTP Waterworks Road Bethesda, Ohio 43719	1:50 p.m.	September 1, 2006
	Exit Time	Permit Expiration Date
	2:10 p.m.	August 31, 2011

Name(s) & Title(s) of On-Site Representative(s)	Phone Number(s)
Name, Address, & Title of Responsible Official	Phone Number
Tim Zdansky, Village Administrator Village of Bethesda P.O. Box 36 Bethesda, Ohio 43719	(740) 391-4201

C. AREAS EVALUATED DURING INSPECTION

<u>S</u> Permit	<u>N</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>N</u> Records/Reports	<u>N</u> Laboratory	<u>N</u> Compliance Schedules
<u>N</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>N</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N</u> Sludge Storage/Disposal	<u>N</u> Other
<u>N</u> Collection System		

(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated; N/A = Not Applicable)


D. EFFLUENT/RECEIVING WATER OBSERVATIONS

<u>Outfall #</u> 001	<u>Oil Sheen</u> None	<u>Grease</u> None	<u>Turbidity</u> None	<u>Visible Foam</u> None	<u>Visible Float Solids</u> None	<u>Color</u> None	<u>Other</u> --
-------------------------	--------------------------	-----------------------	--------------------------	-----------------------------	-------------------------------------	----------------------	--------------------

E. SUMMARY OF FINDINGS/COMMENTS (attach additional sheets if necessary)


Abbot Stevenson, Inspector, Ohio EPA, Southeast District Office

6/23/11
Date


Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

6/24/11
Date