



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 7, 2009

Re: Belmont County
Pennwood Estates WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPH00012*FD
NPDES Permit No. OH0059307
Correspondence (PWW)

Belmont County Commissioners
Belmont County Courthouse
St. Clairsville, Ohio 43956

Dear Commissioners:

We have received your self-monitoring reports covering the months of January through September 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Type	Units	Limit	Reported	Date
August 2008						
001	pH	1D Conc	S.U.	6.5	5.9	8/5/2008
001	pH	1D Conc	S.U.	6.5	5.8	8/6/2008
001	pH	1D Conc	S.U.	6.5	6.0	8/7/2008


- NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We received your report regarding these violations. No additional information or action is required at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in black ink, appearing to read 'Mark Esposito', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Mark Esposito, Director, Belmont County Sanitary Sewer District
c: AS file