



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

December 9, 2010

Re: Guernsey County
ODNR - Salt Fork State Park
Self-Monitoring Report Violations
Correspondence (PWW)

Mr. Chuck Ainsco
ODNR- Salt Fork State Park
14755 Cadiz Road
Lore City, Ohio 43755

Dear Mr. Ainsco:

We have received your self-monitoring reports covering the months of August through October 2010 for the Salt Fork State Park campground facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	8/6/2010
September 2010:						
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	9/26/2010
October 2010:						
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/4/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/5/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/9/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/10/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/17/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/21/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/25/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/27/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/30/2010
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	10/31/2010

*1 D Conc is equal to the maximum daily concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Tara Lee, ODNR, Division of Engineering