



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 19, 2008

**Re: Guernsey County
ODNR - Salt Fork State Park
Self-Monitoring Report Violations
Correspondence (PWW)**

Mr. Todd Dean
ODNR, Salt Fork State Park
14755 Cadiz Road
Lore City, Ohio 43755

Dear Mr. Dean:

We have received your self-monitoring reports covering the months of July through December 2007 for the Salt Fork State Park Lodge and campground wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	7D Qty	5.7	165.026	7/1/2007
001	80082	CBOD 5 day	30D Conc	10	384.925	7/1/2007
001	80082	CBOD 5 day	7D Conc	15	400.	7/1/2007
001	80082	CBOD 5 day	30D Qty	3.8	149.225	7/1/2007
001	80082	CBOD 5 day	7D Qty	5.7	357.818	7/8/2007
001	80082	CBOD 5 day	7D Conc	15	936.	7/8/2007
001	80082	CBOD 5 day	7D Conc	15	200.	7/22/2007
001	80082	CBOD 5 day	7D Qty	5.7	72.672	7/22/2007
August 2007						
001	00530	Total Suspended Solids	30D Qty	4.5	136.576	8/1/2007
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.76	4.67167	8/1/2007
001	80082	CBOD 5 day	30D Qty	3.8	281.333	8/1/2007
001	00530	Total Suspended Solids	7D Qty	6.8	681.3	8/15/2007
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	1.1	9.06129	8/15/2007
001	80082	CBOD 5 day	7D Qty	5.7	1396.66	8/15/2007
September 2007						
001	00400	pH	1D Conc	6.5	6.4	9/15/2007
001	00400	pH	1D Conc	6.5	6.4	9/22/2007
001	00400	pH	1D Conc	6.5	6.4	9/29/2007
ODNR - Salt Fork State Park Campground Facility						
001	31616	Fecal Coliform	30D Conc	200	4347.41	7/1/2007
001	31616	Fecal Coliform	7D Conc	400	2700.	7/1/2007
001	80082	CBOD 5 day	30D Conc	10	11.175	7/1/2007

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	7D Conc	400	7000.	7/15/2007
001	50060	Chlorine, Total Residual	1D Conc	0.011	1.	7/20/2007
001	00530	Total Suspended Solids	7D Conc	18	21.	7/22/2007
001	80082	CBOD 5 day	7D Conc	15	19.7	7/22/2007
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	7/27/2007
001	50060	Chlorine, Total Residual	1D Conc	0.011	.05	7/29/2007
August 2007						
001	00530	Total Suspended Solids	30D Conc	12	15.8	8/1/2007
001	80082	CBOD 5 day	30D Conc	10	20.68	8/1/2007
001	50060	Chlorine, Total Residual	1D Conc	0.011	.06	8/4/2007
001	00300	Dissolved Oxygen	1D Conc	6.0	2.4	8/9/2007
001	00530	Total Suspended Solids	7D Conc	18	47.	8/15/2007
001	80082	CBOD 5 day	7D Conc	15	34.5	8/15/2007
001	00530	Total Suspended Solids	7D Conc	18	25.	8/22/2007
001	80082	CBOD 5 day	7D Conc	15	39.8	8/22/2007
September 2007						
001	80082	CBOD 5 day	7D Conc	15	25.2	9/1/2007
001	80082	CBOD 5 day	30D Conc	10	11.1175	9/1/2007


*1 D Conc is equal to the maximum daily concentration limit.
 7D Conc is equal to the average weekly concentration limit.
 7D Qty is equal to the average weekly loading limit.
 30D Conc is equal to the average monthly concentration limit.
 30D Qty is equal to the average monthly loading limit.

If some of the above violations at the lodge plant were caused by circumstances other than the plant maintenance which we had previously discussed please explain. If some of the violations at the campground plant were caused by something other than the rapid dissolving of the de-chlorination tablets please explain those as well. If you have already provided explanation as to why these violations occurred no response is needed to this letter.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
 District Representative
 Division of Surface Water

JJG/dh

c: Tara Lee, ODNR, Division of Engineering