



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 30, 2009

Re: Guernsey County
Senecaville Lagoons
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PA00089*CD
Correspondence (PWW)

Mayor and Council
Village of Senecaville
P.O. Box 5
Senecaville, Ohio 43780

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of May through August 2009 for the Village of Senecaville's wastewater lagoons. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	2898.27	8/1/2009
001	31616	Fecal Coliform	7D Conc	2000	3000.	8/1/2009
001	31616	Fecal Coliform	7D Conc	2000	2800.	8/8/2009

* 7D Conc is equal to the average weekly concentration limit.
30D Conc is equal to a average monthly concentration limit.

Please provide a response to these violations within **10 days** upon receipt of this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator