



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 24, 2010

Re: Guernsey County
Senecaville Lagoons
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PA00089*CD
Correspondence (PWW)

Mayor and Council
Village of Senecaville
P.O. Box 5
Senecaville, Ohio 43780

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through May 2010 for the Village of Senecaville's wastewater lagoons. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	30D Conc	25	25.5	2/1/2010
March 2010						
001	80082	CBOD 5 day	30D Conc	25	31.75	3/1/2010
April 2010						
001	80082	CBOD 5 day	30D Conc	25	34.75	4/1/2010
001	80082	CBOD 5 day	7D Conc	40	49.	4/1/2010
May 2010						
001	31616	Fecal Coliform	30D Conc	1000	1300.	5/1/2010

* 7D Conc is equal to the average weekly concentration limit.
30D Conc is equal to an average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required. In addition to the above violations some severe odor issues originating in the village's two main lift stations have been documented by area residents. In order to alleviate the odor issues I recently met with your operator Matt Stiers and discussed the importance to resolve the odor issues in a timely manner. Please provide an update on efforts to resolve these odor issues.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator