



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 30, 2009

Re: Guernsey County
Spring Valley Campground
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PR00143*BD
Correspondence (PWW)

Mr. Dan Edmunds, Owner
Spring Valley Campground
8000 Dozer Road
Cambridge, Ohio 43725

Dear Mr. Edmunds:

We have received your self-monitoring report covering the months of May through August 2009 for the Spring Valley campground's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:


Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	1000.	5/1/2009
June 2009:						
001	00530	Total Suspended Solids	30D Conc	12	20.	6/1/2009
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	3.	6/1/2009
001	31616	Fecal Coliform	30D Conc	1000	2467.	6/1/2009
001	00530	Total Suspended Solids	1D Conc	18	20.	6/17/2009
001	31616	Fecal Coliform	1D Conc	2000	2467.	6/17/2009
July 2009:						
001	31616	Fecal Coliform	1D Conc	2000	3833.	7/16/2009

*1 D Conc is equal to maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of the violations has been sent to our office, no further documentation is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Jim Duty, Operator