



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 24, 2010

Re: Guernsey County
Spring Valley Campground
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PR00143*BD
Correspondence (PWW)

Mr. Dan Edmunds, Owner
Spring Valley Campground
8000 Dozer Road
Cambridge, Ohio 43725

Dear Mr. Edmunds:

We have received your self-monitoring report covering the months of August through October 2010 for the Spring Valley campground's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	30D Conc	1000	3070.	9/1/2010
001	31616	Fecal Coliform	1D Conc	2000	3070.	9/15/2010
October 2010						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	2.48	10/1/2010

*1 D Conc is equal to maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,


Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Jim Duty, Operator