



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 9, 2010

Re: Guernsey County
Seneca Lake Campground
Self-Monitoring Report Violations
NPDES Permit #OPX00002*AD
Correspondence (PWW)

Mr. Boris Slogar, Chief Engineer
Muskingum Watershed Conservancy District
1319 Third Street
New Philadelphia, Ohio 44663

Dear Mr. Slogar:

We have received your self-monitoring reports covering the months of November through December 2009 for the Seneca Lake Lagoon wastewater facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	38.	11/1/2009
001	80082	CBOD 5 day	30D Conc	10	15.75	11/1/2009
001	00665	Phosphorus, Total (P)	30D Conc	1.0	1.81	11/1/2009
001	00530	Total Suspended Solids	1D Conc	18	60.	11/2/2009
001	00530	Total Suspended Solids	1D Qty	2.52	2.7252	11/2/2009
001	00665	Phosphorus, Total (P)	1D Conc	1.5	1.81	11/2/2009
001	00530	Total Suspended Solids	1D Conc	18	29.	11/9/2009
001	80082	CBOD 5 day	1D Conc	15	21.	11/9/2009
001	00400	pH	1D Conc	6.5	3.14	11/9/2009
001	00530	Total Suspended Solids	1D Conc	18	25.	11/16/2009
001	80082	CBOD 5 day	1D Conc	15	18.	11/16/2009
001	00530	Total Suspended Solids	1D Conc	18	38.	11/27/2009
001	80082	CBOD 5 day	1D Conc	15	19.	11/27/2009
001	00400	pH	1D Conc	6.5	2.84	11/27/2009
December 2009:						
001	00530	Total Suspended Solids	30D Conc	12	26.5	12/1/2009
001	00665	Phosphorus, Total (P)	1D Conc	1.5	2.26	12/1/2009
001	00665	Phosphorus, Total (P)	30D Conc	1.0	2.26	12/1/2009
001	00530	Total Suspended Solids	1D Conc	18	34.	12/8/2009
001	00400	Ph	1D Conc	6.5	3.38	12/8/2009
001	00530	Total Suspended Solids	1D Conc	18	40.	12/22/2009
001	00400	pH	1D Conc	6.5	6.03	12/22/2009

*1 D Conc is equal to the maximum daily concentration limit.
1 D Qty is equal to the maximum daily loading limit.
30D Conc is equal to the average monthly concentration limit.
30D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111. The above noted violations have been noted for the past several months and new treatment units have been installed within the past year to address the problems.

Please provide an explanation within **30** days upon receipt of this letter of operational measures and actions which will be taken at the facility to address the above noted violations. If you would like further technical assistance you may contact Keith Kroeger in our compliance assistance unit at (740) 836-8778.

If there are any other questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Gary Taylor, Operator, MWCD