



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 30, 2008

**Re: Guernsey County
Byesville Water Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 01Y00100*BD
Correspondence (IWW)**

Mayor and Council
Village of Byesville
221 East Main Street
P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through March 2008 for the Byesville water treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residu	1D Conc	0.019	.06	1/3/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	1/5/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.07	1/9/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.09	1/11/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.07	1/14/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.07	1/16/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	1/17/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.06	1/18/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.11	1/23/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.13	1/24/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.09	1/27/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	1/30/2008
February 2008						
001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	2/4/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	2/6/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.12	2/7/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.09	2/11/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.1	2/13/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.09	2/14/2008

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residu	1D Conc	0.019	.1	2/17/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.12	2/20/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.09	2/21/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.1	2/25/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.1	2/27/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.12	2/28/2008
[March 2008]						
001	50060	Chlorine, Total Residu	1D Conc	0.019	.2	3/3/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.19	3/5/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.17	3/6/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.14	3/12/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.12	3/13/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.11	3/14/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.2	3/17/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.07	3/18/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	3/20/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.07	3/24/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	3/26/2008
001	50060	Chlorine, Total Residu	1D Conc	0.019	.07	3/27/2008

*1 D Conc is equal to the maximum daily concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111. These residual chlorine violations have been reported for six consecutive months and have placed your facility on our significant non-compliance list, which subject you to enforcement action. Please provide documentation of your internal investigation and monitoring to diagnose your problem and efforts to be implemented to correct these violations.

Please submit within 10 days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
 District Representative
 Division of Surface Water

JJG/mlm

c: Thomas McVicker, Superintendent