



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kortesi, Director

November 7, 2008

**Re: Guernsey County
Byesville Water Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 01Y00100*BD
Correspondence (IWW)**

Mayor and Council
Village of Byesville
221 East Main Street, P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of August through September 2008 for the Byesville water treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	8/13/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	8/19/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	8/20/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	8/21/2008
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	9/13/2008

*1 D Conc is equal to the maximum daily concentration limit.

These residual chlorine violations have been reported for nine consecutive months and may subject you to enforcement action. Please provide written documentation describing when the filter beds will be rehabilitated with adequate approved filter sand which should help alleviate permit violations. Documentation verifying the completion of the other measures discussed during a recent site inspection with Mr. McVickers should also be provided. This documentation shall be provided within **10** days upon receipt of this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Thomas McVicker, Superintendent