



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

October 1, 2009

**Re: Guernsey County
Byesville Water Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 01Y00100*BD
Correspondence (IWW)**

Mayor and Council
Village of Byesville
221 East Main Street
P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of May through August 2009 for the Byesville water treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	5/12/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	5/15/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	5/18/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	5/19/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	5/25/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.08	5/27/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.11	5/28/2009
June 2009:						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	6/5/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	6/11/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	6/13/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.07	6/14/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	6/22/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	6/29/2009
July 2009:						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	7/6/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	7/23/2009

*1 D Conc is equal to the maximum daily concentration limit.

Review of the March and April's discharge monitoring reports have shown a significant decrease in the daily residual chlorine concentrations. Please provide written documentation as to what measures were taken and planned actions to ensure residual chlorine concentrations remain in compliance to your permit. This documentation shall be provided within **14** days upon receipt of this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Thomas McVicker, Superintendent