



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korfeski, Director

December 23, 2009

**Re: Guernsey County  
Byesville Water Treatment Plant  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 01Y00100\*BD  
Correspondence (IWW)**

Mayor and Council  
Village of Byesville  
221 East Main Street, P.O. Box 8  
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of July through September 2009 for the Byesville water treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	7/6/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	7/23/2009
<b>September 2009</b>						
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	9/22/2009

\*1 D Conc is equal to the maximum daily concentration limit.

Review of the July through September's discharge monitoring reports have shown a significant decrease in the daily residual chlorine concentrations. Please provide written documentation as to what measures were taken and planned actions to ensure residual chlorine concentrations remain in compliance to your permit. Actions taken thus far to come into compliance are much appreciated. This documentation shall be provided within **14** days upon receipt of this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Thomas McVicker, Superintendent