



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 9, 2010

Re: Guernsey County
Byesville Water Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 01Y00100*BD
Correspondence (IWW)

Mayor and Council
Village of Byesville
221 East Main Street, P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of August through October 2010 for the Byesville water treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:


| Station | Reporting Code | Parameter | Limit Type* | Limit | Reported Value | Violation Date |
|------------------------|----------------|--------------------------|-------------|-------|----------------|----------------|
| 001 | 01044 | Iron, Suspended (Fe) | 30D Conc | 1000 | 1133.5 | 8/1/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .08 | 8/2/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .1 | 8/3/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .11 | 8/6/2010 |
| 001 | 01044 | Iron, Suspended (Fe) | 1D Conc | 2000 | 3870. | 8/18/2010 |
| September 2010: | | | | | | |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .15 | 9/7/2010 |
| October 2010: | | | | | | |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .05 | 10/2/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .05 | 10/4/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .06 | 10/7/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .06 | 10/9/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .05 | 10/14/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .07 | 10/15/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .07 | 10/16/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .07 | 10/20/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .06 | 10/22/2010 |
| 001 | 50060 | Chlorine, Total Residual | 1D Conc | 0.019 | .44 | 10/30/2010 |

*1 D Conc is equal to the maximum daily concentration limit.

Please provide written documentation as to what measures were taken and planned actions to ensure residual chlorine concentrations remain in compliance to your permit. Actions taken thus far to reduce the occurrences of residual chlorine violations are much appreciated. This documentation shall be provided within **14** days upon receipt of this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Thomas McVicker, Superintendent