



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 29, 2010

**Re:** Guernsey County  
Rolling Hills Subdivision WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit No. 0PW00007\*FD  
Correspondence (PWW)

Mr. Philip W. Whitaker, Receiver  
8131 Hillingdon Drive  
Powell, Ohio 43065

Dear Mr. Whitaker:

We have received your self-monitoring reports covering the months of October through December 2009 for the Rolling Hills Subdivision's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.019	.06	10/4/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	10/11/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.09	10/13/2009
001	50060	Chlorine, Total Residual	1D Conc	0.019	.05	10/29/2009

\* 1D Conc is equal to the minimum daily concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. In addition to the above violations it was reported in October that several samples were not collected as well as the reporting of AJ for CBOD in November. The AJ code in the eDMR system is only to be used when the parameter concentration is found to be above the upper limit of an automatic analyzer although this is not the method used for the analysis of biochemical oxygen demand. Please provide an explanation of all the above noted violations.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Tom McVickers, Operator, Village of Byesville