



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 15, 2010

Re: Guernsey County
Rolling Hills Subdivision WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PW00007*FD
Correspondence (PWW)

Mr. Philip W. Whitaker, Receiver
8131 Hillingdon Drive
Powell, Ohio 43065

Dear Mr. Whitaker:


We have received your self-monitoring reports covering the months of May through July 2010 for the Rolling Hills Subdivision's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residu	1D Conc	0.019	.13	5/7/2010
001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	5/8/2010
001	50060	Chlorine, Total Residu	1D Conc	0.019	.27	5/10/2010
001	50060	Chlorine, Total Residu	1D Conc	0.019	.1	5/14/2010
001	50060	Chlorine, Total Residu	1D Conc	0.019	.15	5/23/2010
001	50060	Chlorine, Total Residu	1D Conc	0.019	.07	5/26/2010
001	00400	pH	1D Conc	6.5	6.34	5/31/2010
June 2010						
001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	6/27/2010
July 2010						
001	00400	pH	1D Conc	6.5	6.39	7/16/2010
001	00400	pH	1D Conc	6.5	6.38	7/29/2010

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has already been sent to our office no further correspondence is necessary.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/mlm

c: Tom McVickers, Operator, Village of Byesville