



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

December 9, 2010

Re: Guernsey County
Rolling Hills Subdivision WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PW00007*FD
Correspondence (PWW)

Mr. Philip W. Whitaker, Receiver
8131 Hillingdon Drive
Powell, Ohio 43065

Dear Mr. Whitaker:

We have received your self-monitoring reports covering the months of August through October 2010 for the Rolling Hills Subdivision's wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00300	Dissolved Oxygen	1D Conc	5.0	3.58	8/8/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	3.18	8/9/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	4.18	8/10/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	3.83	8/11/2010
001	00400	pH	1D Conc	6.5	6.38	8/13/2010
001	50060	Chlorine, Total Residual	1D Conc	0.019	.23	8/14/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	8/14/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	4.61	8/19/2010
001	50060	Chlorine, Total Residual	1D Conc	0.019	.17	8/22/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	4.35	8/30/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	4.71	8/31/2010
September 2010						
001	00300	Dissolved Oxygen	1D Conc	5.0	4.75	9/2/2010
001	00300	Dissolved Oxygen	1D Conc	5.0	4.94	9/3/2010
October 2010						
001	00400	pH	1D Conc	6.5	6.41	10/8/2010
001	00400	pH	1D Conc	6.5	6.1	10/19/2010


* 1D Conc is equal to the minimum daily concentration limit for pH and DO; maximum value for chlorine.

Please submit within **10 days** upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Tom McVickers, Operator