



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 9, 2010

**Re:** Coshocton County  
Echoing Hills Village  
Notice of Violation  
Correspondence (PWW)

Mr. Michael Morrow, Maintenance Director  
Echoing Hills Village  
36272 C.R. 79  
Warsaw, Ohio 43844

Dear Mr. Morrow:

Based on review of records since August 1, 2009, Echoing Hills Village was found to have reported the following limit and code violations with respect to compliance with National Pollutant Discharge Elimination System (NPDES) permit 0PR00154\*AD:

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
<b>August 2009</b>					
001	Total Suspended Solids	30D Conc	12	14.	8/1/2009
001	CBOD 5 day	30D Conc	10	35.	8/1/2009
001	CBOD 5 day	1D Conc	15	35.	8/6/2009
001	Dissolved Oxygen	1D Conc	5.0	4.19	8/6/2009
<b>September 2009</b>					
001	Total Suspended Solids	1D Conc	18	21.	9/1/2009
001	Total Suspended Solids	30D Conc	12	21.	9/1/2009
001	CBOD 5 day	1D Conc	15	26.	9/1/2009
001	CBOD 5 day	30D Conc	10	26.	9/1/2009
001	Dissolved Oxygen	1D Conc	5.0	4.09	9/3/2009
001	Dissolved Oxygen	1D Conc	5.0	4.79	9/8/2009
001	Dissolved Oxygen	1D Conc	5.0	4.03	9/15/2009
<b>December 2009</b>					
001	Total Suspended Solids	30D Conc	12	16.	12/1/2009
<b>January 2010</b>					
001	Total Suspended Solids	30D Conc	12	30.	1/1/2010
001	CBOD 5 day	30D Conc	10	11.	1/1/2010
001	Total Suspended Solids	1D Conc	18	30.	1/19/2010


Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Dissolved Oxygen	1D Conc	5.0	3.69	1/19/2010
<b>February 2010</b>					
001	Total Suspended Solids	30D Conc	12	33.	2/1/2010
001	CBOD 5 day	30D Conc	10	15.	2/1/2010
001	Total Suspended Solids	1D Conc	18	33.	2/2/2010
001	Fecal Coliform			AK	8/6/2009
001	Fecal Coliform			AK	9/1/2009

March, April and May 2010 monitoring data is reportedly in compliance with the NPDES permit.

Please note, Permit OPR00154\*AD requires the Owner to report noncompliance as directed by Part III.12.E of the permit which shall contain information listed in Part III.12.B and Part III.12.C.

If you have any questions, please contact me at (740) 380-5272.

Sincerely,



Aaron Pennington  
District Representative  
Division of Surface Water

AMP/dh