

**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

July 21, 2011

**Re:** Coshocton County  
Edgewood Terrace MHP WWTP  
Ohio EPA Permit No. 0PV00022\*BD  
NPDES Permit No. OH0124672  
Notice of Violation  
Correspondence (PWW)

Mr. Ron Morningstar, Owner  
643 North High Street  
Hillsboro, Ohio 45133

Dear Mr. Morningstar:

We received self-monitoring data for the months of September 2010 through June 2011 for the referenced facility. Our review indicates the following limit violations of your NPDES permit.


| Parameter                | Limit Type | Limit  | Reported Value | Violation Date |
|--------------------------|------------|--------|----------------|----------------|
| Chlorine, Total Residual | 1D Conc    | 0.019  | .152           | 9/14/2010      |
| Chlorine, Total Residual | 1D Conc    | 0.019  | .086           | 9/28/2010      |
| Nitrogen, Ammonia (NH3)  | 30D Conc   | 2.0    | 7.89           | 10/1/2010      |
| Nitrogen, Ammonia (NH3)  | 30D Qty    | 0.0757 | .19142         | 10/1/2010      |
| Nitrogen, Ammonia (NH3)  | 1D Conc    | 3.0    | 12.8           | 10/14/2010     |
| Nitrogen, Ammonia (NH3)  | 1D Qty     | 0.114  | .32363         | 10/14/2010     |
| Chlorine, Total Residual | 1D Conc    | 0.019  | .909           | 10/14/2010     |
| Nitrogen, Ammonia (NH3)  | 30D Conc   | 2.0    | 8.665          | 11/1/2010      |
| Nitrogen, Ammonia (NH3)  | 30D Qty    | 0.0757 | .12506         | 11/1/2010      |
| Nitrogen, Ammonia (NH3)  | 1D Conc    | 3.0    | 15.5           | 11/11/2010     |
| Nitrogen, Ammonia (NH3)  | 1D Qty     | 0.114  | .21249         | 11/11/2010     |
| pH                       | 1D Conc    | 9.0    | 9.06           | 5/31/2011      |

This Facility was transferred September 17, 2010 from Caven S. Mcloughlin to Morningstar Investment Properties, LLC. No violations occurred from December 2010 through April 2011.

We have reviewed your non-compliance notifications containing descriptions of the above violations and actions being taken to prevent further occurrences. No additional information is requested at this time.

If you have any questions, please feel free to contact me at (740) 380-5272.

Sincerely,

A handwritten signature in black ink, appearing to read 'Aaron Pennington', written over a horizontal line.

Aaron Pennington  
District Representative  
Division of Surface Water

AMP/dh