



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 30, 2008

Re: Gallia County
Quail Creek Mobile Home Park WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPV00002*ED
NPDES Permit No. OH0041289
Correspondence (PWW/Minor)

Mr. Newton I. Jones, Owner
Quail Creek Mobile Home Park
437 Cora Mill Road
Gallipolis, Ohio 45631

Dear Mr. Jones:

We have received your self-monitoring reports covering the months of July 2007 through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2008:						
001	00530	Total Suspended Solids	30D Conc	12	20.	1/1/2008
001	00530	Total Suspended Solids	30D Qty	1.0	1.02271	1/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	16.4	1/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.33	.83862	1/1/2008
001	80082	CBOD 5 day	30D Conc	12	15.	1/1/2008
001	00530	Total Suspended Solids	7D Conc	18	20.	1/15/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	7.5	16.4	1/15/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Qty	0.62	.83862	1/15/2008
February 2008:						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	7.3	2/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.33	.40479	2/1/2008
March 2008:						
001	80082	CBOD 5 day	30D Conc	12	22.	3/1/2008
001	80082	CBOD 5 day	30D Qty	1.0	1.12415	3/1/2008
001	80082	CBOD 5 day	7D Conc	18	22.	3/15/2008
April 2008:						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	10.3	4/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.33	.49434	4/1/2008
001	00610	Nitrogen, Ammonia (NH3)	7D Conc	7.5	10.3	4/8/2008
May 2008:						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.5	1.9	5/1/2008


- *NOTES:** 1D Conc = Daily Average Concentration Value (mg/l)
1D Qty = Daily Average Loading Value (kg/day)
7D Conc = Weekly Average Concentration Value (mg/l)
30D Conc = Monthly Average Concentration Value (mg/l)
7D Qty = Weekly Average Loading Value (kg/day)
30D Qty = Monthly Average Loading Value (kg/day)

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Unless you have already done so, please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5218.

Sincerely,

Handwritten signature of Dan Messerly in black ink, with the initials 'DM' written below the signature.

Dan Messerly
District Staff Engineer
Permits and Enforcement Section
Division of Surface Water

DM/dh

c: Paul Moss, Operator