



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 7, 2008

Re: Guernsey County
Buffalo Duke and Dutchess
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PR00098*AD
Correspondence (PWW)

Mr. John Gordon
Englefield Oil Company
Mid Ohio Industrial Park
447 James Parkway
Heath, Ohio 43056

Dear Mr. Gordon:

We have received your self-monitoring reports covering the months of August through September 2008 for the Buffalo Duke and Dutchess wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	13.8	8/1/2008
001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.011	.07835	8/1/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	3.0	13.8	8/21/2008
001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.017	.07835	8/21/2008
September 2008						
001	00530	Total Suspended Solids	30D Conc	12	30.	9/1/2008
001	00530	Total Suspended Solids	30D Qty	0.068	.17033	9/1/2008
001	80082	CBOD 5 day	30D Conc	10	22.	9/1/2008
001	80082	CBOD 5 day	30D Qty	0.057	.12491	9/1/2008
001	00530	Total Suspended Solids	1D Conc	18	30.	9/30/2008
001	00530	Total Suspended Solids	1D Qty	0.10	.17033	9/30/2008
001	80082	CBOD 5 day	1D Conc	15	22.	9/30/2008
001	80082	CBOD 5 day	1D Qty	0.085	.12491	9/30/2008

- * 1 D Conc is equal to the maximum daily concentration limit.
- 1D Conc is equal to the maximum daily loading limit.
- 30D Conc is equal to the average monthly concentration limit.
- 30D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111. These effluent limit

violations have been reported for six consecutive months and may subject you to enforcement action. Technical assistance with your plant operation can be provided by calling Keith Kroeger in our compliance assistance unit at (614) 863-8778.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Gary Bennett, Operator