



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 10, 2008

Re: Guernsey County
Village of Byesville
NOV (0PB00004, OH0024287)
Correspondence (PWW)

Mayor and Council
Village of Byesville
221 East Main Street
P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of September 2007 through April 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Outfall	Date	Parameter	Reported	Units	Permit Limitation
October 2007					
001	Week 4	Fecal Coliform	AK	#/100ml	2000
December 2007					
001	Average	Suspended Solids	49	mg/l	30
001	Average	Suspended Solids	160	kg/day	56.8
001	Weeks 1-4	Suspended Solids	94-272	kg/day	85.2
001	Weeks 2&4	Suspended Solids	51-71	mg/l	45
January 2008					
001	Average	Suspended Solids	92.8	kg/day	56.8
001	Week 2	Suspended Solids	51	mg/l	45
001	Week 2	Suspended Solids	224	kg/day	85.2
February 2008					
001	Average	CBOD5	64.2	kg/day	47.3
001	Weeks 1-4	Suspended Solids	96.3-225	kg/day	85.2
001	Average	Suspended Solids	34	mg/l	30
001	Average	Suspended Solids	155	kg/day	56.8
001	Week 2	CBOD5	77.6	kg/day	75.7


Outfall	Date	Parameter	Reported	Units	Permit Limitation
March 2008					
001	Average	Suspended Solids	211	kg/day	56.8
001	Average	CBOD5	65.0	kg/day	47.3
001	Week 1	Suspended Solids	46	mg/l	45
001	Average	Suspended Solids	37	mg/l	30
001	Weeks 1-4	Suspended Solids	129-283	kg/day	85.2
001	Week 3	CBOD5	85.7	kg/day	75.7

We have reviewed your reports addressing the aforementioned loading violations. No additional information is needed at this time for those violations.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte
Chemical Engineer - Environmental Specialist II
Division of Surface Water

JMW/dh

Enclosure