



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 1, 2009

**Re: Guernsey County
Byesville Sewage Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PB00004*FD
Correspondence (PWW)**

Mayor and Council
Village of Byesville
221 East Main Street, P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of May through August 2009 for the Byesville sewage treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	7D Qty	85.2	104.694	5/1/2009
August 2009:						
001	00530	Total Suspended Solids	30D Conc	30	37.375	8/1/2009
001	00530	Total Suspended Solids	7D Conc	45	51.	8/15/2009

* 7D Qty is equal to the average weekly loading limit.
7D Conc is equal to the average weekly concentration limit.
30D Conc is equal to the average monthly concentration limit.

Review of the self-monitoring reports also revealed two permit violations for fecal coliform concentrations in the month of August which were report as AK, too numerous to count. Please provide a written response as to why these violations occurred and actions which will be taken to prevent future occurrences. This documentation shall be provided within 14 days upon receipt of this letter.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Karen Froehlich, Wastewater Superintendent