



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

June 25, 2010

Re: Guernsey County
Byesville Sewage Treatment Plant
Self-Monitoring Report Violations
Ohio EPA Permit No. 0PB00004*FD
Correspondence (PWW)

Mayor and Council
Village of Byesville
221 East Main Street, P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of May through August 2009 for the Byesville sewage treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	38.375	1/1/2010
001	00530	Total Suspended Solids	30D Qty	56.8	62.8485	1/1/2010
001	80082	CBOD 5 day	7D Conc	40	41.	1/1/2010
001	00530	Total Suspended Solids	7D Qty	85.2	110.677	1/22/2010
March 2010:						
001	00530	Total Suspended Solids	30D Qty	56.8	68.5606	3/1/2010
001	00530	Total Suspended Solids	7D Qty	85.2	97.6908	3/22/2010
001	80082	CBOD 5 day	7D Qty	75.7	76.3056	3/22/2010

- * 7D Qty is equal to the average weekly loading limit.
- 7D Conc is equal to the average weekly concentration limit.
- 30D Conc is equal to the average monthly concentration limit.
- 30D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

c: Karen Froehlich, Wastewater Superintendent