



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 2, 2008

**Re:** Guernsey County  
City of Cambridge  
Notice of Violation  
OPD00020, OH0024309  
Correspondence (PWW/Major)

Mr. Paul Sherry, P.E., City Engineer & Utilities Director  
City of Cambridge  
1131 Steubenville Avenue  
Cambridge, Ohio 43725-2599

Dear Mr. Sherry:

We have received your self-monitoring reports covering the months of November 2005 through March 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:


Outfall	Date	Parameter	Reported	Units	Permit Limitation
<b>November 2006:</b>					
001	Week 4	Suspended Solids	1119	kg/day	511
001	Week 4	CBOD5	1114	Kg/day	454
<b>February 2007:</b>					
001&601	Week 2	Suspended Solids	2/week	mg/l	Monitoring required 3/week
001&601	Week 2	CBOD5	2/week	mg/l	Monitoring required 3/week
001	Week 2	Ammonia	2/week	mg/l	Monitoring required 3/week
<b>April 2007:</b>					
001	Week 3	Oil and grease	11	mg/l	10
<b>March 2008:</b>					
001	Week 1	Suspended Solids	680	Kg/day	511

Please inform this office in writing within **ten** days of receipt of this notification as to the reasons for the aforementioned referenced violation, as well as a description of actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5206.

Sincerely,



Jennifer M. Witte  
Chemical Engineer, Environmental Specialist II  
Division of Surface Water

JMW/dh