



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 9, 2009

**Re: Guernsey County
Mental Health Center WWTP
Self-Monitoring Report Violations
Ohio EPA Permit No. OPH00013*CD
Correspondence (PWW)**

Guernsey County Board of Commissioners
627 Wheeling Avenue
Suite 300
Cambridge, Ohio 43725-2251

Dear Board of Commissioners:

We have received your self-monitoring reports covering the months of January through April 2009 for the Mental Health Center wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	33.	2/1/2009
001	00530	Total Suspended Solids	7D Conc	45	60.	2/22/2009
March 2009:						
001	00530	Total Suspended Solids	30D Conc	30	62.5	3/1/2009
001	00530	Total Suspended Solids	7D Conc	45	72.	3/1/2009
001	00530	Total Suspended Solids	7D Conc	45	72.	3/8/2009
001	00530	Total Suspended Solids	7D Conc	45	58.	3/15/2009
001	00530	Total Suspended Solids	7D Conc	45	48.	3/22/2009

* 7D Conc is equal to a weekly average concentration limit.
7D Qty is equal to the weekly average loading limit.
30D Conc is equal to a monthly average concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior response was sent regarding these violations no additional information is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey
District Representative
Division of Surface Water

JJG/dh

- c: Clarence Ridgely, Superintendent, Guernsey Co. Water and Sewer Department
- c: Dennis Dougherty, Operator, Guernsey Co. Water and Sewer Department