



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

June 25, 2010

**Re:** Guernsey County  
Couto's Pizza and Subs  
Self-Monitoring Report Violations  
NPDES Permit #0PR00099\*CD  
Correspondence (PWW)

Mr. Larry Couto  
P.O. Box 313  
Buffalo, Ohio 43722

Dear Mr. Couto:

We have received your self-monitoring reports covering the months of January through April 2010 for Couto's Pizza and Subs wastewater treatment facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	30D Conc	10	12.	1/1/2010
<b>February 2010:</b>						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	8.7	2/1/2010
001	80082	CBOD 5 day	30D Conc	10	20.	2/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	6.0	8.7	2/3/2010
001	80082	CBOD 5 day	1D Conc	15	20.	2/3/2010
<b>March 2010:</b>						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	10.3	3/1/2010
001	80082	CBOD 5 day	30D Conc	10	23.	3/1/2010
001	00610	Nitrogen, Ammonia (NH3)	1D Conc	6.0	10.3	3/3/2010
001	80082	CBOD 5 day	1D Conc	15	23.	3/3/2010
<b>April 2010:</b>						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	4.0	5.37	4/1/2010
001	80082	CBOD 5 day	30D Conc	10	15.	4/1/2010


- \* 1D Qty is equal to a maximum daily loading limit.
- 1D Conc is equal to the maximum daily concentration limit.
- 30 D Conc is equal to average monthly concentration limit.
- 30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,



Jake Greuey  
District Representative  
Division of Surface Water

JJG/dh

c: Matt Stiers, Operator